

No. DGPC/CPD/CMPD/18(1)/2019/248

August 28, 2019

CORRIGENDA/ADDENDA No. 1

Bidding Document : Repair of Spillway Glacis and Stilling Basin of Kurichu Hydropower Plant

Tender No. : CO0015 dated 05.08.2019

Reference : Minutes of the Pre-bid meeting dated 20.08.2019

In accordance with the provisions under Clauses 11.2, 11.3, 13.4, 14.1 and 14.2 of 'Information & Instruction for Bidders' under Section II of the Bidding Document, the following Corrigenda/Addenda is hereby issued for modification of the Bidding Document:


1) SECTION – VI : TECHNICAL SPECIFICATIONS & DRAWINGS

a) C: Technical Specifications

- i) Under Item No. 4.3: Materials for concrete, the maximum size of aggregate for M25 and M35 Grade of Concrete under the 'Concrete Mix Designation' indicated as '40 mm' is hereby deleted and replaced with '20 mm'.
- ii) Under Item No. 7.7.2 (d), pertaining to anchoring to be done after concreting, the words appearing as "cement grout or other materials as approved by Project Manager" is hereby modified to be read as "epoxy grout".

b) E: Drawings

- i) Under Drawing No.DGPC-SP-09: Glacis and Pier Wall Lining Details, the words appearing as "Expansive Cement Steel Grouted Dowels" is hereby modified to be read as "Epoxy Grouted Steel Dowels".
- ii) Under Drawing No.DGPC-SP-12: Typical Steel Plate and Strip Sections and Drawing No.DGPC-SP-13: Steel Lining Plate and Strip Anchorage Details, the words appearing as "Expansive Cement Grouted Steel Dowels" is hereby modified to be read as "Epoxy Grouted Steel Dowels".
- iii) Under Drawing No.DGPC-SP-14: Connection Details of Plate, Strips and Dowels, the words appearing as "Expansive Cement Grouted" is hereby modified to be read as "Epoxy Grout".



- iv) Drawing No.DGPC-SP-14(a) pertaining to Grout Hole and Plug Details is hereby issued as addenda to the Bidding Document.
- 2) **SECTION VII A : BIDDING FORMS**
- a) **Form 16A : Bill of Quantities**
- i) Under item No. B (1.3) and B (2.6) pertaining to providing and fixing 25mm dowel (Grade E250 A/BR/BO), the words appearing as “grouting with non-shrinking material” is hereby modified to be read as “epoxy grouting the hole”.

Head (Contracts Management and Procurement Division)

Contracts & Procurement Department, DGPC

Thimphu, Bhutan

(Email: t.wangchuk792@drukgreen.bt)

(Tel: +975-2-339875)