

CLARIFICATIONS TO BIDDER'S QUERIES

Name of Tender : Replacement of Unit II and Unit IV Generator along with ancillaries of all units of CHP

Reference No. : No. DGPC/CMPD/CPD/17-A/2022/103 April 25, 2022

SN	Clause Reference	Clause Description	Bidder's Query	DGPC Reply
1	Section II: Shortlisting Criteria, xxiii (a)	<p>In case of Bids submitted by a Merged/Acquired/Subsidiary Company, the qualification requirements shall be as under:</p> <p>a) Commitment by the Parent/Holding company to sign a separate agreement with the Employer (i.e. DGPC) confirming their full support for the technical and financial requirements of the Merged/Acquired/Subsidiary Company and to take up the work itself in case of non-performance by the Merged/Acquired/Subsidiary Company in the event of award of the work</p> <p>b) Parent/Holding Company shall submit an undertaking letter along with the Bid that, in case the Merged/Acquired/Subsidiary Company is awarded the work on the strength of the Parent/Holding Company, the Parent/Holding Company shall furnish an additional Performance Bank guarantee for an amount equivalent to 5% of the awarded work value, in addition to the normal Performance Bank Guarantee to be submitted by the successful Bidder</p>	<p>With reference to clause in EOI Section II: Shortlisting Criteria, point xxiii) regarding qualification of the bidder on the basis of Parent Company, we would like to mention following.</p> <p>In the earlier tender for E&M work of Nikachhu Hydropower Project, following clause related to Parent/holding Company was mentioned,</p> <p>"Subsidiaries can be an applicant on behalf of the Parent/holding Company qualifying the criteria. The applicant must enclose the documentary evidence of having had the support of and access to the assets and resources of a "Parent/holding company" for this contract package through a Corporate Guarantee of any other proper documents to the satisfaction of Employer. Past experience and financial capacity of such Parent/holding company may be considered for qualification of such subsidiary company. All the warrantees and guarantees as required in the Bidding Document shall be provided by Parent/holding Company"</p> <p>Therefore, we request DGPC to amend the Parent Company clause (Section II: Shortlisting Criteria, Point xxiii)) with same clause as in Nikachhu tender.</p>	<p>EOI Provisions shall prevail.</p> <p>The existing provisions under Clause xxiii (a) and (b) adequately covers all the requirements related to submission of Bid by Merged/Acquired/Subsidiary Company.</p>

2	EOI Section II: Shortlisting Criteria 7 (c)	Understanding of the tentative Completion Time and Milestones (provided by CHP) and compliance to the same by the bidders. The bidder may comment or proposed their own scheduling but it shall be acceptable to DGPC	<p>As this is a service and rehab project, so a reverse engineering / existing condition of equipment is must to design the new compatible equipment. Therefore, contractor required the additional time for reverse engineering, So, kindly add a line item for Reverse Engineering, which required additional 3 months</p> <p>With reference to the Request for EOI, we would like to inform DGPC that the works specified in the enquiry is of complex nature & there is requirement of quality reverse engineering of generator for 84 MW machine with involvement of VOITH Generator Global design team. After duly design of generator set and drawing approval from DGPC, VOITH shall manufacture & supply high quality Generator without any compromise. Considering Hydro Generator as critical equipment in power plant & requirement, we wish to inform DGPC that we need more time for reverse engineering & designing of Generator than that specified in enquiry. We hereby enclosing our proposed completion schedule for your review & acceptance.</p>	<p>As indicated in the EOI, Bidder shall propose their own schedule as per their manufacturing capability/engineering time requirements.</p> <p>The intent of this clause is to finalize Completion time based on the proposals submitted by bidders.</p>
3	-	-	Please confirm that all units (I to VI) are of identical design.	<p>All the Units are identical except for the following:</p> <p>i) The top and bottom brackets along with LGB and UGB of Unit I and Unit II were replaced in 2011/2013 and are different from Unit III and Unit IV. The</p>

			<p>We assumed that all generator units are same and identical.</p>	<p>brake/jack system of Unit I and Unit II were also replaced along with the brackets and is different from that of Unit III and Unit IV.</p> <p>ii) The complete generator stator (including frame, core and winding) and rotor field coils for Unit I and Unit III are replaced and is different from Unit II and Unit IV. The generator air coolers for Unit I and Unit III were also replaced.</p>
--	--	--	--	--